



TEST CERTIFICATE No. 2009-098-C1

Test Client	Certificate Issue Date
VELUX Australia Pty Ltd 321-323 Princes Highway St.Peters NSW 2044	9 November 2010

Introduction
The roof window described below was tested by this laboratory on behalf of the test client in accordance with the nominated subclauses of the stated standard and achieved the results shown below. Refer to the referenced test report(s) for full sample details and compliance information.

Product Name	Test Standard	Test Date
FCM 4646 0004B	AS 4285-2007 (refer below for test clauses)	9 November 2009

IBA Report	Description of product
2009-098-S5	The system was nominally 1300mm x 1300mm OD secured to a metal base and metal flashing. Installation was in accordance with VELUX FCM installation instructions VAS 452195-0109. Glazing 3.9mm toughened outer/12 Argon/2.5-0.76-2.5 laminated inner
3.2.2.5: Watertightness	Result: Pass at 0°, 15°, 27° & 60° roof pitches

IBA Report	Description of product
2009-098-S6	The system was nominally 1300mm x 1300mm OD secured to a timber hob without flashing. Installation was in accordance with VELUX FCM installation instructions VAS 452195-0109. Glazing 3.9mm toughened outer/12 Argon/2.5-0.76-2.5 laminated inner
3.2.2.2: Resistance to Concentrated Loads	Result: Pass
3.2.2.3: Resistance to Wind Pressure (non-cyclone)	Result: Pass (+7.2 & -7.3 kPa ULS)
3.2.2.4: Resistance to Wind Pressure (cyclone)	Result: Pass (-5.0 kPa ULS)

NOTES
THIS CERTIFICATE IS PROVIDED FOR GENERAL INFORMATION ONLY AND DOES NOT COMPLY WITH THE REGULATORY REQUIREMENTS FOR EVIDENCE OF COMPLIANCE
Reference should be made to the relevant test report(s) to determine the applicability of the test result to a proposed installation.

TEST LABORATORY	IAN BENNIE and ASSOCIATES Pty Ltd	ACN: 007 133 253
Address:	1 Luisa Avenue, Dandenong, VIC 3175	
Phone / Fax:	03 9768-3640 / 03 9768-3642	
Prepared by:	Ian Bennie	