



Postal Address:
PO Box 4282
Dandenong South, Victoria 3164
Australia

Testing. Advising. Assuring.

EWFA CERTIFICATE OF TEST	CERTIFICATE No : SFC 2391800.1	Page 1 of 1
---------------------------------	---------------------------------------	--------------------



Report Sponsor	Certificate Issue Date
Velux Australia Pty Ltd 321-323 Princes Highway, St Peters, NSW, 2044.	8/01/10

Introduction
The element of construction described below was tested by this laboratory on behalf of the test sponsor in accordance with the stated test standard and achieved the results stated below. Refer to the referenced test report for more information.

Referenced Report	Test Date	Test Standard
EWFA 2391800.2	19/11/2009	AS1530.8.1-2007.

Description of Product		
Product name	Test Specimen Arrangement	Rating
Velux FCM 4646 0004B Skylight	The system was nominally 1305mm x 1300mm in size and supported by a timber framed roof with corrugated steel roof sheeting. The fascia and gutter were steel. Refer to the test report for a full description.	BAL 40

Notes
THIS CERTIFICATE IS PROVIDED FOR GENERAL INFORMATION ONLY AND DOES NOT COMPLY WITH THE REGULATORY REQUIREMENTS FOR EVIDENCE OF COMPLIANCE.
Reference should be made to the relevant test report to determine the applicability of the test result to a proposed installation.
The results of these fire tests may be used to assess fire hazard, but it should be recognised that a single test method will not provide a full assessment of fire hazard under all conditions.

TESTING AUTHORITY	Exova Warringtonfire Aus Pty Ltd
Address	PO Box 4282 DANDENONG SOUTH VIC 3164 Unit 2, 409-411 Hammond Road, DANDENONG VIC 3175
Phone / Fax	+61 (0) 3 9767 1066 / +61 (0) 3 9767 1001
ABN	81 050 241 524
Email / Home Page	www.exova.com
Authorisation	Prepared By:  Reviewed By:  C. M. McLean K. G. Nicholls